

**Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The CITY OF RENO water system PWS ID 1390013 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This/These violation(s) occurred in the monitoring period(s) **JANUARY 2016 DUE TO 4TH QUARTER 2015 REPORT WAS FILED LATE. ATTACHED YOU WILL FIND A COPY OF THE REPORT.**

We are taking the following actions to address this issue: Reports will be mailed in a timely manner.

Please share this information with all the people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses.) You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact Jerry Reavis, Public Works Supervisor at 903-785-6851.

Posted/Delivered on: **5/6/2016**



DISINFECTANT LEVEL QUARTERLY OPERATING REPORT (DLQOR)
FOR GROUNDWATER OR PURCHASED-WATER PUBLIC WATER SYSTEMS-ANY SIZE

Select Quarter:

Select Year:

PWS Name: City of Reno	PWS ID: 1390013
-------------------------------	------------------------

Type of Disinfectant Used in Distribution System*:

* If you used chloramines and free chlorine at any time during this quarter, select both.

First Month of Quarter: Monthly Summary

Month: October

Was the PWS active this month? YES NO

Average of all disinfectant residuals for this month	Number of residuals collected this month	Number below MIN for this month	Number with NO residual for this month
1.93 mg/L	62 readings	0 readings 0.0 %	0 readings 0.0 %

Second Month of Quarter: Monthly Summary

Month: November

Was the PWS active this month? YES NO

Average of all disinfectant residuals for this month	Number of residuals collected this month	Number below MIN for this month	Number with NO residual for this month
1.71 mg/L	58 readings	0 readings 0.0 %	0 readings 0.0 %

Third Month of Quarter: Monthly Summary

Month: December

Was the PWS active this month? YES NO

Average of all disinfectant residuals for this month	Number of residuals collected this month	Number below MIN for this month	Number with NO residual for this month
1.84 mg/L	62 readings	0 readings 0.0 %	0 readings 0.0 %

Quarterly Summary and Certification

Average of all disinfectant residuals for this quarter	Lowest residual for this quarter	Highest residual for this quarter
1.83 mg/L	0.80 mg/L	2.80 mg/L

I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.

Name: Jerry Reavis

Enter Name

Signature

Today's

Date:

4/18/16

Title: Public Works Supervisor

Phone Number: (903) 785-6581

License #: WD0002069

Email address: jerry@renotexas.us

Complete this form for the previous quarter at the beginning of April, July, October, and January; and submit in time for it to be received by the TCEQ by the 10th of the month. Always print and sign form, and keep a copy with your records for TCEQ review.

Step 1:

Print Copy

(For your own records)

Step 2:

Print to Mail

Sign and Mail to:
TCEQ / PDW MC-155
Attn: DLQOR
PO Box 13087
Austin, TX 78711-3087

Click the button below to start over or to reset to enter data for a different system.

Clear Form